HUNTINGTON POWER

HPE WORK ORDER

Completed by:	STEVE ALLEN	**Completed:**	12/19/2022 17:13	**AS-LEFT:**	OPERATIONAL
HPE Dispatch #:	83447	**2nd Tech:**	0		
Customer Number:	0013107	**Location Number:**	8	**Location Name:**	BERLIN GARAGE 130KW
Site Address:	27 TOWN FARM RD	**City:**	BERLIN	**State:**	CT
Location Notes:					
Generator MFG:	GENERAC	**Engine MFG:**	NEW HOLLAND	**ATS MFG:**	NA
Generator Model #	99A-06077-S	**Engine Model #:**	7.5L	**ATS MODEL #:**	NA
Generator SN #:	2051176	**Engine SN #:**	NA	**ATS SERIAL #:**	NA
Generator SPEC #:	NA	**Engine SPEC:**	NA	**Fuel**	Diesel
Generator Hours	52.5	**Controller**	E-Panel	**kW**	130
PMSC Model#	NA	**PMSC SN#**	NA	**Firmware Version**	NA

ISSUE/COMPLAINT

UNIT HAS BEEN SITTING IN STORAGE FOR 10 YEARS. ON SITE TO CLEAN UNIT CHANGE COOLANT, REPLACE HEATER HOSES, CHANGE OIL, ALL FILTERS AND LOAD BANK TEST

WORK ORDER DESCRIPTION

INSTALLED CUSTOMER SUPPLIED BATTERY. CHANGED AIR FILTER. CHANGED FUEL FILTERS, CHECKED FLUID LEVELS AND STARTED ENGINE DOES START AND GEN HAS VOLTAGE OUTPUT. SHUT DOWN AND DRAINED COOLANT. REPLACED 5/8TH HEATER HOSES. CHANGED OIL AND OIL FILTER. FILLED WITH NEW COOLANT, BLED AND PRESSURE TESTED SYSTEM. INSTALLED NEW RADIATOR CAPS. CLEANED ENGINE AND BASE TANK. RAN UNIT UNDER LOADBANK WITH NO ISSUES. LEFT UNIT IN OFF WITH NEG BATTERY CABLE DISCONNECTED

PARTS ADDED

PART #	DESCRIPTION	QTY	COMMENTS	RESTOCK	HAZMAT
001	[N] 836-99107-36 1 Gal 15w-40 Motor Oil	6			Peachtree Part
FC10100	Coolant, Fltcharge PG 50/50 (0J7959)	6			Peachtree Part
33166	Fuel Filter (0670570363)	2			Peachtree Part
090625	Air Cleaner 7 3/4 (46759)	1			Peachtree Part
096701	Filter Oil (51775) (VZ096701)	1			Peachtree Part
050967	Hose Cool 5/8 Id 20r3	6			Peachtree Part
32310	10S SS SILICONE HOSE CLAMPS\CR	10			Peachtree Part
090283	Cap Radiator 13 Psi	1			Peachtree Part
046627	Cap Radiator 14psi	1			Peachtree Part