

December 17, 2019



Bid #2020-08

Electronic Community Sign
Addendum #3

Q: Can you tell me from where the sign will draw power, is there a building nearby that an electrician can get power from and run an underground conduit to the sign?

A: Our electrician confirmed the following:

- Existing 208/120 Volt Single Phase Panel on site next to sidewalk
- 3 spaces available in panel
- Existing 120volt 20 amp breaker feeding the current sign through ½ " pvc conduit underground. 20' from panel to existing sign.